

should be based on planning projections derived from an official source. Any deviations should be based on sound engineering judgment substantiated in the engineering report.

Table G2-1. Design Basis for New Sewage Works

Discharge Facility	Design Units	Flow* (gpd)	BOD (lb/day)	SS (lb/day)	Flow Duration (hr)
Dwellings	per person	100	0.2	0.2	24
Schools with showers and cafeteria	per person	16	.04	.04	8
Schools without showers and with cafeteria	per person	10	.025	.025	8
Boarding schools	per person	75	0.2	0.2	16
Motels at 65 gal/person (rooms only)	per room	130	0.26	0.26	24
Trailer courts at 3 persons/trailer	per trailer	300	0.6	0.6	24
Restaurants	per seat	50	0.2	0.2	16
Interstate or through-highway restaurants	per seat	180	0.7	0.7	16
Interstate rest areas	per person	5	0.01	0.01	24
Service stations	per vehicle serviced	10	0.01	0.01	16
Factories	per person per 8-hr shift	15-35	0.03-0.07	0.03-0.07	Operating period
Shopping centers	per 1,000 sq ft of ultimate floor space	200-300	0.01	0.01	12
Hospitals	per bed	300	0.6	0.6	24
Nursing homes	per bed	200	0.3	0.3	24
Homes for the aged	per bed	100	0.2	0.2	24
Doctor's office in medical center	per 1,000 sq ft	500	0.1	0.1	12
Laundromats, 9 to 12 machines	per machine	500	0.3	0.3	16
Community colleges	per student and faculty	15	0.03	0.03	12
Swimming pools	per swimmer	10	0.001	0.001	12
Theaters, drive-in type	per car	5	0.01	0.01	4
Theaters, auditorium type	per seat	5	0.01	0.01	12
Picnic areas	per person	5	0.01	0.01	12
Resort camps, day and night, with limited plumbing	per campsite	50	0.05	0.05	24
Luxury camps with flush toilets	per campsite	100	0.1	0.1	24

*Includes normal infiltration

G2-1.3 In-Plant Piping and Channels

All piping and channels should be designed to carry the maximum expected flows. The incoming sewer should be designed for free discharge. Bottom corners of the channels should be filleted and pockets and corners where solids can accumulate should be eliminated. Isolation gates should be placed in channels to seal off unused sections where sewage solids might accumulate.